
302 B - 11

Commercial Complax, Ranjeet Nagar, New Delhi- 110008 Phone 011 - 25700168, 9099554242

email : dwtl@watersupermart.com • www.delhiwatertestlab.com







## TEST GERTIFICATE

Test Certificate No.: DWGTL/22-23/106 EC					Issue Date:	18/08/2022
Party's name: AN Autonation Car Products Pvt Ltd M-127, Guru Harkrishan Nagar Paschim Vihar, New Delhi-110087  Date of Sample Receipt: 16/08/22					Ref. No.:	Nil
					Protocol Used:	IS:10500-2012
					Lab code:	DWGTL/22-23/106 EC
Sample Collected by: Party			Types of water: Water Sample		Testing Duration :	16/08/22 to 18/08/22
Physical analysis	S.N	Parameters		Test Results	Requirements	Test method Used
	1.	Color		< 4	5	IS:3025 Pt-4-2002
	2.	Odor		Disagreeable	Agreeable	IS:3025 Pt-5-2002
	3.	Taste		Disagreeable	Agreeable	IS:3025 Pt-8-2006
	4.	Turbidity, NTU		0.4	1	IS:3025 Pt-10-2006
	5.	pH		8.31	6.5-8.5	IS:3025 Pt-11-2002
	6.	Total Dissolved Solid, mg/l		359	500	IS:3025 Pt-16-2002
Chemical analysis	7.	Total Iron as Fe, mg/l		0.12	0.3	IS:3025-Pt53-2009
	8.	Total Hardness as CaCO <sub>3,</sub> mg/l		115	200	IS:3025 Pt-21-2009
	9.	Chlorides as Cl, mg/l		65.2	250	IS:3025 Pt-32-2002
	10.	Residual Free chlorine, mg/l		Nii	0.2	IS:3025 Pt-26-2003
	11	Sulphate as SO4, mg/l		21.5	200	IS:3025pt-24-2009
	12	Fluorides as F-, mg/l		0.26	1.0	IS:3025-Pt60-2003

Checked by Sr. Chemist

Authorized signatory

## WE UNDERTAKE TESTING OF : WATER \* AIR \* EFFLUENTS \* MATERIALS

The above result are related only to the sample. Endorsement of products is neither inferred nor implied, this report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media with out our special written permission. Samples will be destroyed after 15 days from the date of reporting unless otherwise specified.

Total liability of laboratory is limited to the invoiced amount

Approved by the Municipal Coporation of Delhi (Health Deptt)